


Panel



Industrial & commercial applications may require the installation of a LOCKOUT/TAGOUT device to prevent the kiln from operating during maintenance.

This kiln is recommended to be wired & connected to an approved U. L. & NEC configured receptacle controlled with a disconnect switch and properly fused according to the kW load specification listed on the kiln nameplate. L&L Kiln Mfg., Inc., also recommends fuses rather than circuit breakers to prevent nuisance tripping.

Wiring Information	
Power	10AWG / 150°C / 600V
Control	16AWG / 105°C / 600V
Power Supply Wire Gauge assumes 75°C Copper Wire. See hotkilns.com/wire-size	

Model: e14S-240	
Voltage	240 / 1 / 50-60
Watts	3,840
Full Load Amps	L1 L2 L3
	16.0 16.0
Power Supply	Fuse Wire
	20A 14AWG
Elements	QTY OHMS
E-F-1418/31	4 14.4

E14S Easy-Fire 1 Phase 240V 240V



505 Sharptown Road
Swedesboro NJ 08085
service@hotkilns.com
(856)-294-0077

Drawn by: JS

C0002

Rev. Date Description